

**LINCOLN COUNTY
DEPARTMENT OF ENVIRONMENTAL HEALTH
WASTEWATER TREATMENT AND DISPOSAL SYSTEM PERMIT**

Issue Date: 7/29/2008

Expiration Date: 7/29/2009

Property Owner: Will Hendricks

c/o: Barbara Renkema

Address: 175 Indian Creek Road

Telephone: (Home) 297-7857

(Work)

Installer: Barbara Renkema

License No. 78

Proposed Work: (Check One) ☒ New Installation ☐ Existing System

☐ Repair ☐ Replacement ☐ Extension ☐ Other

Describe: Installing three 65-foot lines with 25% reduction in drainfield size for infiltrators.

Parcel Description:

Legal: S6 T36N R26W

Address or Location: Fatt Boy Subdivision Lot 1

Approved Design Criteria:

Bedrooms 4 Septic Tank Size: 1500 Gallons Drainfield Size: 195 Linear Feet

SYSTEM MUST INCLUDE INSTALLATION OF EFFLUENT FILTER AT SEPTIC TANK OUTLET !!

Special Instructions: INSTALL SYSTEM ACCORDING TO LAYOUT AND LINCOLN COUNTY WASTEWATER REGULATION #3. ANY DEVIATIONS FROM APPROVED PLAN MUST BE AUTHORIZED BY THE DEPARTMENT.

Issued By: *Lori Kelley-Bowe, R.S.*

Closure Statement:

I, _____, have inspected this system and found it to be in compliance with the conditions of the permit, and the Lincoln County Wastewater Treatment and Disposal Regulation.

Signed: _____

Date: _____

Title: _____

NOTICE: The Department must be notified at least 48 hours prior to backfilling the system. Any system not inspected by the Department or its designated representative prior to closure is an illegal installation in violation of Lincoln County Health Board Regulation No. 3. Illegal installations may result in fines and/or requirements to remove or reconstruct the system.

406-293-7781

DISCLAIMER

This permit is not a guarantee by the Department that the system will function properly for a prescribed period of time.

Fat Boy Sub
S 6 T36^N R26^W

North

